



SMS User 's Guide Models & Algorithms



© LBMP GFC Inc.

2002

COPYRIGHT

© Copyright 2002 Global Power & Financial Consulting Inc.

All rights reserved. Without limiting the rights under copyright, no part of this document may be reproduced, stored in or introduced into a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), or for any purpose, without the express written permission of Global Power & Financial Consulting Inc.

TERMS OF USE

THIS DOCUMENT IS PROVIDED FOR INFORMATION PURPOSES ONLY.

The information contained in this document represents the current views of GPFC Inc. on the issues discussed as of the date of publication. Because we must respond to change in the market conditions, information is subject to change without notice.

INFORMATION PROVIDED IN THIS DOCUMENT IS PROVIDED 'AS IS' WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND FREEDOM FROM INFRINGEMENT.

GPFC Inc. used its best efforts in preparing this material, but makes no representation or warranties with respect to accuracy or completeness of the contents. No information in this document should be interpreted to be a commitment on the part of GPFC Inc.. GPFC Inc. shall in no event be liable for any loss, loss of profit or any other damage, including but not limited to special, incidental, consequential, or other damages. THE USER ASSUMES THE ENTIRE RISK AS TO THE ACCURACY AND THE USE OF THIS DOCUMENT.

OTHER IMPORTANT INFORMATION

All examples, names used herein are for illustration purposes only. No association with any real event, name or value is intended or should be inferred.

CONTACT

Global Power & Financial Consulting Inc. ♦ gpfc@bellnet.com ♦ 416 • 971 • 6938
2 Ross Street, Toronto, Ontario, CANADA, M5T-1Z9

TABLE OF CONTENTS

TABLE OF CONTENTS	2
1. <u>BACKGROUND:</u>.....	4
2. <u>AN OVERVIEW OF SMS INPUT-OUTPUT RELATIONSHIP</u>	5
3. <u>HOW TO ACTIVATE THE SMS SUITE</u>.....	6
4. <u>HOW TO PREPARE INPUT DATA FOR A SMS RUN</u>	9
A) PHASE ANGLE REGULATOR (PHASE SHIFTER) ADJUSTMENT:	9
B) TRANSMISSION LIMIT ADJUSTMENT & TRANSMISSION OUTAGE DATA:.....	10
C) DAILY GENERATOR OUTAGE DATA:	16
D) IMPORT-EXPORT ADJUSTMENT	18
E) BID AND ASK MODIFICATIONS:	19
F) HOW TO PREPARE PRIMARY DEMAND INPUT:.....	22
G) RUN_SMS:.....	24
4. <u>SMS OUTPUTS</u>	27
A) SPOT MARKET PRICE FORECASTS:.....	27
B) FLOWGATE 'S FLOWS:.....	29
C) CONGESTED FLOWGATES & FTR VALUES:	30
<u>APPENDIX A: FLOW-GATE DEFINITIONS</u>	33

USER 's GUIDE

1. Background:

The power industry today has undergone drastic and irreversible changes. From a monopolistic environment a decade ago when electricity was generated and distributed to consumers who had virtually no say in the prices, electricity is now traded in a competitive market just like other commodities; and consumers today can select and buy electricity from marketers of their choice.

Because electricity cannot be stored in a large quantity, it must be generated to meet the instantaneous demand. The spot market clearing prices of electricity market sometimes can behave quite unpredictably. Quite often, spot market price volatility is attributed to the capacity adequacy and demand conditions of a Control Area. In addition, the underlying transmission network within a Control Area and between adjacent Control Areas can result in price disparity between regions. Limitations of a transmission network often prevent power flow from inexpensive to more expensive regions. As a result, more expensive resource must be dispatched to meet the local demand resulting in higher market clearing price in that region. The challenge is to devise a dispatch algorithm, which maximizes the utilization and value of available resources based on the offer prices to satisfy the demands in different regions while respecting the transmission limitations.

The deregulated electric industry clearly requires a new tool to assist energy traders, asset managers, and system operators. make important decisions in their daily activities. Factors such as generation outages, transmission congestion, volatile fuel costs, load growth and environmental issues/cost must be taken into consideration in forecasting the electricity price.

Furthermore, for some investors who plan for long-term asset acquisitions or divestiture it is important to understand the location impact of the asset on the prices and how it affects their return of the investment. A new tool must be able to simulate the market conditions over a period of 5-10 years with hourly resolution in order to examine in details all possibilities before making such an important decision. In this case the location of the generators in the transmission grid is of paramount importance. The electricity price difference between the two locations is a signal of transmission congestion and it is also a measure of the transmission right value.

SMS Suite, when subscribed with the appropriate Control Areas, is the tool that was developed for these purposes. It is capable of performing network analysis and forecasting electricity spot market prices. It provides also short-term and long-term values of generating assets located anywhere in the Northeastern power network. SMS incorporates variables such as fuel costs, transmission outages, generation outages, weather uncertainty and planned and forced outage rates in order to provide comprehensive answers to some of the difficult questions related to portfolio management and trading decisions. This user's guide will introduce users to various features designed in the SMS Suite and how to use them.

An overview of the SMS input and output relationship is as shown in Figure 1.

2. An Overview of SMS Input-Output Relationship




Figure 1: SMS Suite Input Output Relationship


3. How To Activate the SMS Suite

MS Suite is developed based on Matlab¹ technology to take advantage of many convenient features such as userfriendliness, rich mathematical algorithms, speed and variety of sophisticated computational platforms. However, users do not need to know Matlab in order to run SMS, although some basic knowledge of Matlab would help them navigate through the inputs and outputs to get the desired answer more quickly.

Input and output data flows in SMS are handled through the EXCEL interfaces.

To run SMS Suite, users must go to the directory where a working copy of the user-interface template (an EXCEL² worksheet) is installed and follow the following steps:


1. Activate the MS EXCEL workbook named SMS_Database4Use_IMOPD
2. Activate Matlab,
 - by first going to the **Tools** bar Menu and selecting Macro as shown in the picture below:




¹ A Mathworks product: see Mathworks website: www.mathworks.com

² A Microsoft product: see Microsoft Website: www.microsoft.com

- Click on **Macros** and then type 'matlabinit' (**matlab initialize**) in the space provided for the Macro Name as in the picture below



Now everything is ready for you to run the SMS application. You must, however, prepare the input case for your particular study before submitting it to a SMS run. The following sections will guide you through the process of data preparations.



There are 7 worksheets in the **SMS_Database4Use_IMOPD** workbook; they contain the database that will be used to simulate the spot market price forecasts and transmission right evaluation by the SMS suite. The description of each of these worksheets is listed in the following.

1. **NDF4NEpars_info**: this worksheet contains the processed data of the Northeast transmission network into zones of interest as defined by IMO/ISO. The data in this worksheet should not be changed unless there is a change in the transmission network topologies. This worksheet also contains critical planning flowgates' limits.
2. **NDF4pars**: this worksheet contains the operational data for all the phase angle regulators (phase shifters) of the northeast interconnection. All phase angles of the phase shifters are assumed fixed. Users, however, can make changes to a particular phase shifter operation/angle if they have such knowledge.
3. **AdjTXLim**: this worksheet contains flowgates limits and facilities. Adjust these limits to reflect prevailing conditions.
4. **dailyGenOut**: this worksheet contains generating laminations in each zone and facilities that allow the capacity to be adjusted to reflect the availability.
5. **Import_Export**: this worksheet is used to control the import-export amount of power through each control area during the SMS runs.
6. **BID_ASK**: this worksheet contains information about the zonal generating capacity and offer that are categorized into laminations for fuel types and running cost plus a variety of adders.
7. **SMS_run**: this template prepares the input read and other information like holidays, control of specific period to be forecasted etc.

Except for the transmission network topologies that are assumed unchanged, therefore, data in the **NDF4Nepars_info** worksheet will not be modified. The network topologies are considered undergone a major change if there is an expansion due to additions of components such as new transmission lines, new high voltage transformers, or new phase shifters that will have a new major yet unknown impact on the transmission system operations and reliability. Minor changes such as element outages (lines or transformers) for maintenance purposes (whose impacts on the system are known) will be taken into consideration by making appropriate changes in the **AdjTXLim** worksheet. In the following sections we will describe how to prepare input data as required for SMS runs.

4. How To Prepare Input Data for a SMS Run

Before any price forecasts run using SMS, a natural question comes to mind is whether there are any changes in the transmission network that might affect the spot prices. Any change in the flowgate's control devices such as phase shifters (**NDF4pars** worksheet) or change in the flowgate's security limits (**AdjTXLim** worksheet) due to some transmission line outages during the period of study will likely affect the power flows and hence the spot prices of electricity. If users have knowledge of such changes, then they must make appropriate modifications to reflect these changes or the results will not be accurate.

a) Phase Angle Regulator (Phase Shifter) Adjustment:

The default operating conditions of the existing phase shifters are described in the **NDF4pars** worksheet that is partially shown as below

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S
1					NDF4par	TEM	LHE	EWFE	D501P	P502X	FN_S	QFW	BLIP	FETT	MH-ON	ONT-M	ONT-M	ONT-NVHTxON	
2					Preflow	178	148	162	0	0	173	264	460	-250	200	0	459	-263	0
3	Area	Type	OrigBH	BusNAM	Pars(MV)	1	2	3	4	5	6	7	8	9	10	11	12	13	14
4	13	2	99800	LND PR N	98	0	0	0	0	0	0	0	0	0	0	0	0	0	0
5	13	2	99801	LND PR T	-98	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6	13	2	99802	NFM PR N	-351	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7	13	2	99803	NFM PR T	350	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	13	2	99804	NFS PR N	-351	0	0	0	0	0	0	0	0	0	0	0	0	0	0
9	13	2	99805	NFS PR N	350	0	0	0	0	0	0	0	0	0	0	0	0	0	0
10	13	2	99806	WA1 PR T	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11	13	2	99807	WA1 PR N	1	0	0	0	0	0	0	0.259	0.259	0	0	0	0.259	-0.259	0
12	13	2	99808	WA2 PR T	-30	0	0	0	0	0	0	0	0	0	0	0	0	0	0
13	13	2	99809	WA2 PR N	30	0	0	0	0	0	0	0.259	0.259	0	0	0	0.259	-0.259	0
14	13	2	99810	WA3 PR T	-26	0	0	0	0	0	0	0	0	0	0	0	0	0	0
15	13	2	99811	WA3 PR N	26	0	0	0	0	0	0	0.259	0.259	0	0	0	0.259	-0.259	0
16	852	2	99816	MN7 PR N	-110	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
17	852	2	99817	MN7 PR T	110	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
18	852	2	99818	IFLSPR N	0	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
19	852	2	99819	IFLSPR T	0	0.89	0.741	0.81	0	0	0.866	-0.461	0.539	-1.276	0	-1	0.539	0.461	0
20	853	2	99820	BDX PR N	100	0	0	0	0	0	0	-0.081	-0.081	0	0	0	-0.081	0.081	0
21	853	2	99821	BDX PR T	-100	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
22	853	2	99822	MCP1PR N	-57	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
23	853	2	99823	MCP1PR T	58	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
24	853	2	99824	MCP2PR N	-57	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
25	853	2	99825	MCP2PR T	57	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
26	853	2	99826	SCT PR N	-47	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
27	853	2	99827	SCT PR T	47	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
28	853	2	99828	SHE PR N	-67	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
29	853	2	99829	SHE PR T	67	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
30	853	2	99830	WHT1PR N	-100	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
31	853	2	99831	WHT1PR T	100	0.89	0.74	0.81	0	0	0.866	-0.461	0.539	-1.276	1	0	0.539	0.461	0
32	853	2	99832	WHT2PR N	-100	0	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	0
33	853	2	99833	WHT2PR T	100	0.89	0.74	0.81	0	0	0.866	-0.461	0.539	-1.276	1	0	0.539	0.461	0

The flowgate that monitors the power flow between Ontario and Manitoba is controlled by the pairs of phase shifters at the White Shell buses as seen in the red circle in the above picture. The model of a phase shifter is described in Part II: Models & Algorithms. For each phase shifter a pair of generators (one positive, one negative) is used. The flow in this flowgate is regulated to around 200MW. Therefore, we can observe there exist 2 pairs or four generators to represent the two phase shifters along this flowgate. To adjust the phase shifter so that it will operate and therefore control the flow in this flowgate at a different value than 200 MW one must adjust to outputs of these generators. The diagram below illustrate the case where the phase shifters are adjusted to control the flow in the flowgate at a value of 150 MW,

30	853	2	99830	WHT1PR N	-75	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	
31	853	2	99831	WHT1PR T	75	0.89	0.74	0.81	0	0	0.866	-0.461	0.539	-1.276	1	0	0.539	0.461
32	853	2	99832	WHT2PR N	-75	0	0	0	0	0	-0.082	-0.082	0	0	0	-0.082	0.082	
33	853	2	99833	WHT2PR T	75	0.89	0.74	0.81	0	0	0.866	-0.461	0.539	-1.276	1	0	0.539	0.461
34	400	1	00004	FLORIDA N	250	0	0	0	0	0	0	0	0	0	0	0	0	0

Note that although in the above example each generator is assumed to contribute 75 MW to make up the total of 150 MW as specified, it may not necessary be the case. If one has a precise knowledge of the actual setting that is used to control the flowgate's flow, then this setting must be used for the phase shifters.

b) Transmission Limit Adjustment & Transmission Outage Data:

At any given moment, there are always flows in all the branches of an electrical transmission network unless they are completely taken out of service. To operate the power system reliably, one must observe the amount of flow in some lines or a set of lines that are being identified as critical flow-gates to make sure that the flow should not exceed the pre-established limits called security limits in these flow-gates.

What is a Flowgate ?

Flow-gate is a circuit or a group of circuits through which amount of power flow must be monitored and controlled to ensure a safe operation of the power system.

Flow-Gates' Definitions

The Ontario-Michigan flow-gate definition consists of the following circuits:

OH-MECS:

Bus NAME	kV	Bus NAME	kV	Cct. ID	Metered
LAMB L4D	345	19SC67	345	1	T
LAMB L51	345	19SC67	345	1	F
J5D PS	230	19WTRMN	230	1	F
SCOTT	220	19BUNCE	230	1	T

This flow-gate contains four circuits. Consider the first circuit as specified in the first row: the first bus name is an Ontario bus of the circuit (line), next is the voltage level of this circuit, 345 kV; the second bus name is a Michigan bus of the circuit, the voltage level (345 kV), and the circuit identification (Cct. ID). Each circuit of this flow-gate will have a meter for monitoring the flow. The last column indicates where the meter is located. For this circuit, the meter is at the 'TO' bus (T). The symbol 'F' means the meter is located at the 'FROM' bus.

A complete set of flow-gate definitions is shown in the Appendix A.

The template for use to modify transmission limits and transmission outage data is as shown in the EXCEL worksheet named **AdjTXLim** that is partially shown as below

No	Interface	LoLIMIT	UpLIMIT	1	2	3	4	5	6	7	8	9	10
				5/18/02	5/19/02	5/20/02	5/21/02	5/22/02	5/23/02	5/24/02	5/25/02	5/26/02	5/27/02
1	TEM	-350	325	0	0	0	0	0	0	0	0	0	0
2	LHE	-250	230	0	0	0	0	0	0	0	0	0	0
3	EWFE	-350	325	0	0	0	0	0	0	0	0	0	0
4	D501P	-1500	1500	0	0	0	0	0	0	0	0	0	0
5	P502X	-1500	1500	0	0	0	0	0	0	0	0	0	0
6	FN_S	-1800	1265	0	0	0	0	0	0	0	0	0	0
7	QFW	-1600	2650	0	0	0	0	0	0	0	0	0	0
8	BLIP	-2500	4500	0	0	0	0	0	0	0	0	0	0
9	FETT	-5000	5750	0	0	0	0	0	0	0	0	0	0
10	MH-ONT	-200	300	0	0	0	0	0	0	0	0	0	0
11	ONT-MPL	-150	175	0	0	0	0	0	0	0	0	0	0
12	ONT-MECS	-2214	2344	0	0	0	0	0	0	0	0	0	0
13	ONT-NYPP	-1525	2350	0	0	0	0	0	0	0	0	0	0
14	NTxONT_STL	-200	400	0	0	0	0	0	0	0	0	0	0
15	NY_CxE	-3100	2980	0	0	0	0	0	0	0	0	0	0



For each flow-gate, there is a limit for the amount of power flow in one direction and a limit for the flow in the opposite direction. These limits are not necessarily the same due to operating conditions in different areas.

Again, let consider the ONT-MECS flow-gate as marked by the arrow in the above table. The maximum allowable power flow from Ontario to Michigan is 2344 MW whereas the maximum flow from Michigan to Ontario is 2214 MW (-2214 is used to indicate the flow

in the opposite direction). These limits can be modified by directly changing the values of the appropriate cells.

The flow-gates' limits could be varied during the course of the day or week or month due to system conditions. The new limits will be posted by the ISO/IMO as required by market rules to inform the market participants of system changes so that they could take appropriate measures to mitigate the risk created by these changes. These limit changes for various interfaces during days or weeks or months into the future could be captured in the dispatches using the EXCEL table shown above. In the following section, we will demonstrate how SMS utilizes transmission outage information reported daily by the New York ISO prior to its energy dispatch and price forecast runs.

The New York ISO, for example, posts daily transmission limits for various flow-gates throughout the state. A sample of this posting is as shown below.

NYISO TRANSFER LIMITATIONS
Wednesday, June 12, 2002 to Sunday, July 07, 2002

Seasonal Limits
CENTRAL EAST 3100MW STABILITY LIMIT/ 2800 VOLTAGE TRANSFER LIMIT
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPRBRK/DUN SOUTH 4700MW
DYSINGER EAST 2850MW
WEST CENTRAL 2350MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NY1 LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limits. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Circuit NAME	Effective O/S dates	Outage Status	By	Effective Date	Flowgate	New Flowgate's Limit	Original Flowgate's Limit
Y50 DUNWOODIE 345-SHORE RD 345 KV O/S	Sat 05/18/02 to Sat 07/20/02 3:12 Continuous 23:59	UPDATED	by LI	06/04/02	CONED-LIPA New York City-Long Island	800 MW 600 MW	1400 MW
31-PR PORTER 230-ROTTERDAM 230 KV O/S	Mon 06/10/02 to Fri 06/14/02 8:00 Continuous 16:00				CENTRAL EAST Central-Capital/Hudson Valley	500 MW 560 MW	560 MW
M54 W.49TH ST 345-E.13TH ST A 345 KV O/S	Wed 06/12/02 to Thu 06/13/02 20:00 Continuous 4:00	CANCELLED	by CE	06/11/02	SPR/DUN-SOUTH Dunwoodie/Sprainbrook-NYC	3800 MW 700 MW	4500 MW
45 E.13TH ST A 345-FARRAGUT 345 KV O/S	Wed 06/12/02 to Wed 06/12/02 20:00 Daily 20:30	CANCELLED	by CE	06/11/02	SPR/DUN-SOUTH Dunwoodie/Sprainbrook-NYC	3800 MW 700 MW	4500 MW
45 E.13TH ST A 345-FARRAGUT 345 KV O/S	Thu 06/13/02 to Thu 06/13/02 3:30 Daily 4:00	CANCELLED	by CE	06/11/02	SPR/DUN-SOUTH Dunwoodie/Sprainbrook-NYC	3800 MW 700 MW	4500 MW
PA302 BECK B 345-NIAGARA 3 345 KV O/S	Fri 06/14/02 to Fri 06/14/02 9:00 Daily 16:00				IMO-NYISO IMO South-NYISO	1200 MW 1200 MW	2400 MW
14-EN EDIC 345-NEW SCOTL 77 345 KV O/S	Sat 06/15/02 to Sat 06/15/02 8:00 Daily 16:00				CENTRAL EAST Central-Capital/Hudson Valley	4425 MW 1225 MW	5650 MW

How to use this information:

The first row is the circuit name that connects a bus named DUNWOODIE 345 to the SHORE RD 345KV. The second row shows the effective out-of-service dates. It indicates that between May 18, 2002 to July 20, 2002, the circuit named DUNWOODIE 345 _SHORE RD 345KV is out of service (O/S), therefore, the flow-gate between CONED and LIPA whose original limit of 1400MW is to be reduced by 600 MW. This information is entered into the **AdjTXLim worksheet** as shown in the following:

No	Interface	LoLIMIT	UpLIMIT	1	2	3	4	5	6	7	8	9	10
				5/18/02	5/19/02	5/20/02	5/21/02	5/22/02	5/23/02	5/24/02	5/25/02	5/26/02	5/27/02
28	NYCxLILCO	-500	250	0	0	0	0	0	0	0	0	0	0
29	WSCHEXLILC	-800	1400	-600	-600	-600	-600	-600	-600	-600	-600	-600	-600
30	NPXxLILCO	-100	100	0	0	0	0	0	0	0	0	0	0
31	PJM_WxCAP	-1500	1500	0	0	0	0	0	0	0	0	0	0
32	PJM_ExNYC	-1000	1000	0	0	0	0	0	0	0	0	0	0
33	PJM_WxNIAG	-550	550	0	0	0	0	0	0	0	0	0	0
34	PJM_WxCENT	-1100	1100	0	0	0	0	0	0	0	0	0	0
35	HQxADIR	-2350	2350	0	0	0	0	0	0	0	0	0	0
36	NEPOOLxNY	-1375	1300	0	0	0	0	0	0	0	0	0	0


For each day from 5/18/02 to 5/27/02 (10 days used in the table for illustration purposes), The limit on the interface is reduced by 600MW. Thus, the flow from Weschester to Long Island must be kept at 800MW maximum, and the reverse flow from Long Island to Weschester must be controlled at 200MW maximum. SMS will use these new limits when it dispatches power to serve the load demands. Similarly, other flow-gates' limits must be updated to achieve correct results.

In order for the new daily limit change reported in this worksheet to take effect, one must set the **AdjTxLim** parameter in the **BID_ASK worksheet** to 1 as shown below

The screenshot shows the Microsoft Excel interface for the file 'SMS_DataBase4Use_IMOPD.xls'. The active cell is AU4, containing the value '1'. The tooltip for this cell reads: 'Administrator: AdjTxLim: 1: means use adjustable Interface Flow Limits 0: means use old InterfaceFlow Limits Must provide a matrix 'SCLim' with [NoInterface x NoHrs] for adjusting the Interface Limits hourly'. A text box below the tooltip states: 'Enter Options as necessary in the above cells in sheet (SMS_run) to run'.

Note also that this **AdjTXLim** worksheet contains the flowgates' limit in one direction as defined in the column named **UpLIMIT** (positive direction) and the limits in the reverse direction as in the column named **LoLIMIT** (negative direction). These are operational limits as compared to the planning limits shown in the **NDF4NEpars_info** worksheet.

To use the planning limits, one must set the **NuTxLimit** parameter in the **BID_ASK worksheet** to 0, and to use the operational limits set it to 1 (see the below figure).



For comparison, the two sets of limit (planning limits and operational limits) for the defined critical flowgates are also shown in the following page.


From the NDF4NEPARS_info worksheet

From the AdjTXLim worksheet

Planning Flowgates' Limits				Operational Flowgates' Limits			
No	Interface	LoLIMIT	UpLIMIT	No	Interface	oLIMIT	pLIMIT
1	TEM	-350	325	1	TEM	-350	325
2	LHE	-250	230	2	LHE	-250	230
3	EWFE	-350	325	3	EWFE	-350	325
4	D501P	-1500	1500	4	D501P	-1500	1500
5	P502X	-1500	1500	5	P502X	-1500	1500
6	FN_S	-1800	1265	6	FN_S	-1800	1265
7	QFW	-1600	1650	7	QFW	-1600	1650
8	BLIP	-1500	3500	8	BLIP	-1500	3500
9	FETT	-5000	5750	9	FETT	-5000	5750
10	MH-ONT	-200	300	10	MH-ONT	-200	300
11	ONT-MPL	-150	175	11	ONT-MPL	-150	175
12	ONT-MECS	-2214	2344	12	ONT-MECS	-2214	2344
13	ONT-NYPP	-1525	2350	13	ONT-NYPP	-1525	2350
14	NTxONT_STL	-200	400	14	NTxONT_STL	-200	400
15	NY_CxE	-3100	3100	15	NY_CxE	-3100	3100
16	NY_WxC	-2350	2350	16	NY_WxC	-2350	2350
17	NYxPJM	-3600	3600	17	NYxPJM	-3600	3600
18	PJM-WEST	-5750	5750	18	PJM-WEST	-5750	5750
19	PJM-CENT	-4500	4500	19	PJM-CENT	-4500	4500
20	PJM-EAST	-7000	7000	20	PJM-EAST	-7000	7000
21	FRONT-GENE	-2750	2750	21	FRONT-GENE	-2000	2600
22	GENExCENT	-2200	2200	22	GENExCENT	-1300	1770
23	ADIRxCENT	-2050	2050	23	ADIRxCENT	-1500	2500
24	CENxCAP_HD	-4650	4650	24	CENxCAP_HD	-4650	4650
25	CAPxNE	-1200	1200	25	CAPxNE	-1200	1200
26	CAPxWSCH	-4225	4225	26	CAPxWSCH	-4225	4225
27	WSCHExNYC	-4175	4175	27	WSCHExNYC	-2000	3700
28	NYCxLILCO	-975	975	28	NYCxLILCO	-500	250
29	WSCHExLILC	-1175	1175	29	WSCHExLILC	-500	1300
30	NPXxLILCO	-200	200	30	NPXxLILCO	-100	100
31	PJM_WxCAP	-1150	1150	31	PJM_WxCAP	-1500	1500
32	PJM_ExNYC	-1000	1000	32	PJM_ExNYC	-1000	1000
33	PJM_WxNIAG	-1100	1100	33	PJM_WxNIAG	-550	550
34	PJM_WxCENT	-1300	1300	34	PJM_WxCENT	-1100	1100
35	HQxADIR	-2350	2350	35	HQxADIR	-2350	2350
36	NEPOOLxNY	-1375	1300	36	NEPOOLxNY	-1375	1300
37	PJM-APS	-1500	4000	37	PJM-APS	-1500	4000
38	PJM-CEI	-700	700	38	PJM-CEI	-700	700
39	PJM-VP	-2000	2000	39	PJM-VP	-2000	2000
40	APS_WxE	-5000	5000	40	APS_WxE	-5000	5000
41	ADIR-VERMH	-125	150	41	ADIR-VERMH	-125	150
42	NYxONT_NIA	-1975	1325	42	NYxONT_NIA	-1975	1325
43	DECO_CONS	-5324	5324	43	DECO_CONS	-5324	5324
44	DECO_AEP	-3380	3380	44	DECO_AEP	-3380	3380
45	CONS_AEP	-4450	4450	45	CONS_AEP	-4450	4450
46	CONS_CIN	-60	60	46	CONS_CIN	-60	60

c) Daily Generator Outage Data:

Due to the proprietary nature of generator outage data, SMS uses the combined planned and forced outage rates (PFO factors) for all areas of interest represented in the model. This PFO rate is used as the standard deviation in a Random Normal distribution whose mean value is set to zeros. The set of random numbers generated by this distribution is used to offset the available capacity of generation in each zone so that the overall net capacity achieved the desired level. To use this approach users must set the **GenOutage** Parameter in the **BID_ASK** worksheet to 0 and the **PFO factors** to the combined planned and forced outage rates (in fraction). For instance, if the combined planned and forced outage rate is around 15 percent of available capacity in each lamination/zone, then we must set the parameters as shown



If, however, users have precise knowledge of generation outage for each zone, then this info can be entered manually in the provided **dailyGenOut** worksheet as shown partially in the following diagram.

Each zone in the SMS program contains 10 cells. These cells are also called laminations which are used to classified the type of generations exists in each zone.

Note that each zone shown in the diagram is exactly the transpose of each zone energy lamination described in the **BID_ASK** worksheet. The reason for the transpose is so that daily outages for each zone lamination can be accommodated.

Suppose, there is approximately 200 MW out of a total capacity of 2850 MW of nuclear power in Zone PS of the PJM market to be out of service for the next 4 days, the information can be entered into the **dailyGenOut** worksheet as shown in the diagram.

Zone PS of the PJM. Each zone has 10 laminations

Daily amount of power outage within the fuel -type lamination of the zone

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R
4			BaseMW	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
5	1	PS	224	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6	2	2	2850	-200	-200	-200	-200	0	0	0	0	0	0	0	0	0	0	0
7	3	3	2042	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	4	4	536	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
9	5	5		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
10	6	6		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11	7	7	949	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12	8	8	4843	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
13	9	9	975	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
14	10	10	900	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
15	11	NE	512	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
16	12	2	2648	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
17	13	3	746	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
18	14	4	28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
19	15	5	1055	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
20	16	6	1191	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
21	17	7	1058	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
22	18	8	2000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
23	19	9		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
24	20	10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
25	21	PL	24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
26	22	2	152	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
27	23	3	2217	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
28	24	4	2000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
29	25	5	310	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Another way to incorporate outages is to reduce the amount of MW available in the **BID_ASK** worksheet by moving the generation capacity to a much high price lamination. Usually the last lamination in each zone is set aside for this purpose. Due to high its high price, it will not normally dispatched. Hence, by moving generation capacity to this lamination one is essentially increasing the outage rate for that zone.

d) Import-Export Adjustment

Optimal power dispatches will result in power flowing from a cheaper zone to a more expensive zone to meet load demands. In practice, free movement of power based on price offer alone is not realistic. Other factors such as dispatch coordination, security and system reliability must also be considered during the dispatches.

Within the authority of an ISO/ IMO it makes sense to assume that normal economic dispatch takes place with some minor adjustment for security reasons. However, power exchange between IMO and ISO or ISO and ISO must be coordinated to ensure proper dispatches. So unless power traders are actively involved in moving surplus cheap power to supply more expensive demand regions, free power movement based on offer price simply does not occur.

In SMS program, import and export feature is facilitated in a worksheet named **Import_Export** as shown below

ISO/IMO	PJM	MECS	NY	ON	NE	HQ
CAIEBase	1000	-600	-1300	800	-700	800
1	1023	-501	-900	1086	578	881
2	1147	-503	-878	1195	532	865
3	1095	-506	-1066	1060	572	974
4	868	-547	-1001	1123	648	1023
5	1134	-514	-1148	1337	559	871
6	967	-458	-1050	1379	567	915
7	1066	-457	-880	1186	596	1049
8	985	-478	-992	1384	564	865
9	910	-502	-937	1264	633	980
10	1013	-580	-1102	1010	595	932
11	877	-514	-957	1207	578	954
12	1073	-606	-864	1077	662	961
13	1032	-578	-1071	1435	630	1186
14	886	-489	-1119	1066	638	940
15	890	-504	-800	1141	628	968

Use this row to enter data for import (-) or export (+) if one only knows approximately maximum amount during the period of study

Use the table to enter data for import (-) or export from each IMO/ISO if one has daily info of maximum import and export amount in each area

In the example shown, during the period of forecast, one would expect that at any hour PJM could export a maximum of 1000 MW, MECS imports a maximum 600 MW, NY could buy up to 1300MW, Ontario could sell up to 800 MW, New England could buy up to 700MW and HQ could sell up to 800 MW.

The table format is designed for a forecast period of 15 days ahead; however, it could be easily extend to any number of days with some minor change.

e) BID and ASK Modifications:

One of the challenges in forecasting spot market price is the lack of data concerning bidding strategies. Because of the proprietary nature of how generators offer their energy to the daily or hourly spot markets, one must establish some reasonable criteria based on the public domain information related to the generation characteristics in each IMO/ISO in order to forecast the spot market prices for electricity.

Public domain information such as fuel type, heat rates, and operating characteristics is available for most generators. This information together with the historical price data in various control areas and ISO/IMO published price data can be used to construct a bidding strategy for generators.

The BID_ASK worksheet shows generator data categorized into fuel type, capacity and the estimated cost per MWh for all generators across the Northeast interconnection.

The screenshot shows an Excel spreadsheet with the following structure:

- Columns:** A through AI. Key sections include:
 - LOAD BIDDING:** Columns G (RefLd), H (SpotBid).
 - ENERGY BIDDING LAMINATIONS: SpotGMW:** Columns N through V (MW 1-10), W (FuelAd), X (GenCap), Y (ASK 1-10), Z (ASK 1-10), AA (ASK 1-10), AB (ASK 1-10), AC (ASK 1-10), AD (ASK 1-10), AE (ASK 1-10), AF (ASK 1-10), AG (ASK 1-10), AH (ASK 1-10), AI (BidFat).
 - PRICE BIDDING LAMINATIONS: SpotAsk:** Columns Y through AI (ASK 1-10, BidFat).
- Rows:** 1 through 39. Rows 5-39 contain generator data with various values in the bidding and price columns.

Except for Ontario IMO market where the amount of generating capacity is not classified according to the fuel-type but rather by station, The US generating capacity is listed by fuel type. The order of fuel-type shown is:

1. Water or Hydro-electric type
2. Uranium or Nuclear type
3. Bituminous or Coal-fired type
4. Wood
5. Refuse or Waste
6. Others (Anything else that is not of the type listed)
7. Methane Gas
8. Natural Gas
9. Fuel Oil #6
10. Fuel Oil #2 or mixed type

Corresponding to the table of “Energy Bidding Laminations” is the “Price Bidding Laminations” table. The entries in one table are mapped one-to-one in the corresponding table. For ease of discussion, let us consider the very first row of the table shown in the BID_ASK worksheet as shown below:

LOAD BIDDING:		ENERGY BIDDING LAMINATIONS: SpotGMW										PRICE BIDDING LAMINATIONS: SpotAsk													
RefLd	SpotBid	Zone	fwdrnk	MW 1	MW 2	MW 3	MW 4	MW 5	MW 6	MW 7	MW 8	MW 9	MW 10	GenCap	ASK 1	ASK 2	ASK 3	ASK 4	ASK 5	ASK 6	ASK 7	ASK 8	ASK 9	ASK 10	BidFac
				Water	Uran	Bitum	Wood	Refus	Other	Methan	Nat.G	FO #6	FO #2	FuelAdj											
				Water	Uran	Bitum	Wood	Refus	Other	Methan	Nat.G	FO #6	FO #2	Water	Uran	Bitum	Wood	Refus	Other	Methan	Nat.G	FO #6	FO #2		
-8836	250	PS	0	224	2850	2042	536			949	4843	975	900	13318	12	14	19	24			51	51	85	1500	1.00

224 MW of hydro-electric capacity is offered to the spot market at \$12/MWh

Zonal load BID Price to be served (some load will be shed if the price is higher than this price)

Zonal load during Summer peak 2000 load

These factors are used to adjust the OFFER price for each fuel-type generator. (see details on how to adjust the price in the next box below)

This factor is used to adjust the OFFER price for ALL the generators in the ZONE. The default value is 1 which means no adjustment is required. Use a factor > 1 to increase the OFFER price and < 1 to decrease the OFFER price. The factor must always be positive

As shown in the above diagram, the worksheet contains information about the zonal generating capacity and offer that are categorized into laminations for fuel types and running cost that also includes a variety of adders to account for actual cost plus profit.

SMS suite also allows dispatchable load BIDS. That is, the load can specify up to what price it is willing to pay for the power it consumes every hour. If it happens that the spot market price for some hour is higher than its bid price, some dispatchable load could be shed from the total load to achieve the desired price. This feature is very useful for implementing the demand management strategy to avoid rotating blackout, especially during the energy shortage period.

Although the load reference for each zone is reported in the table, it should not be taken as though the energy consumption is fixed for each zone during the study period. This reference serves as sanity check for the zonal load forecasts and “**Fwdmkt**” modeling that will be discussed shortly. The SMS program requires that hourly zonal load must be supplied for the entire period of the study. This data is read into the program in a separate input file to be discussed later.

The SMS program also provides bidding flexibility for fuel-type base for the entire region. The factors in the very top row of the Price Bidding Lamination table are to be used for the fuel-type based OFFER adjustment, and the factors in the far right column are used for zonal energy OFFER price adjustment. These factors must always be positive.

To increase the OFFER price one must use a factor that is greater than 1 and to decrease the price use a factor that is less than 1. The factor of value 1 is the reference for the OFFER prices as shown in the “Price Bidding Lamination” table.

One final feature from this worksheet that is also worth mentioning here is the “**Fwdmkt**”. The fourth column from the left that was labeled “**Fwdmkt**” is used to signal whether the generators in a particular zone should be used as “forward” market or not. That is, if the zone is considered as “**Fwdmkt**” either because we do not have sufficient data for generators in that zone or it is far away and therefore is not of interest, but activities in this zone will have some impact in the network power flow. Therefore we must find a way to incorporate the effect of these zonal activities. By assigning this zone to the “**Fwdmkt**” type, one basically assumes that the zone has enough supply to satisfy its own load (here summer peak load is used as a reference) and simulates the impact of the power flow in other flowgates of interest as a result. In doing this one at least capture some power flow impact in other critical flowgates in a conservative way rather than not capturing the effect at all that might result in erroneous congestion estimate.

To include a particular zone in the spot market dispatch, one therefore must assign 0 to the corresponding row of the “**Fwdmkt**” column. And the generating data of the zone must be supplied together with the OFFER prices in both “Energy Bidding Laminations” and “Price Bidding Laminations” tables for proper dispatches. On the other hand, if the zone is to be excluded from the spot market dispatch, then a 1 must be entered in the appropriate row. No information about generation needs to be provided.

f) How to Prepare Primary Demand Input:

Before showing how to run the SMS program, let us consider how the primary demand input should be prepared. Hourly primary demand for each zone must be prepared and arranged in the order as shown in the template below:

Two zones for Michigan:
 1. Detroit Edison
 2. Consumer Power

Eleven zones for New York ISO:
 1. A 2. B 3. C
 4. D 5. E 6. F
 7. G 8. H 9. I
 10. J (New York City)
 11. K (Long Island)

Nine zones for Ontario IMO:
 1. NIAG 2. SW 3. BRUCE
 4. ESSA 5. NE 6. NW
 7. EAST 8. TO 9. WEST

Hrs	DECO	CONS	A	B	C	D	E	F	G	H	I	J	K	NIAG	SW	BRUCE	ESSA	NE	NW	EAST	TO	WEST
1																						
2																						
3																						
4																						
5																						
6																						
7																						
8																						
9																						
10																						
11																						
12																						
13																						
14																						
15																						
16																						
17																						
18																						
19																						
20																						
21																						
22																						
23																						
24																						
25																						
26																						
27																						
28																						
29																						
30																						
31																						
32																						
33																						
34																						
35																						
36																						
37																						
38																						
39																						
40																						
41																						

The primary demand input may contain as many hours as users want for their price forecast simulation. The SMS Suite does not restrict the size of the primary demand input.

The best way to load the primary demand input into SMS Suite is through Excel Link. Once the data has been prepared in the specified format in an EXCEL worksheet, it can be read in using the Excel Link command **putmatrix**:

1. Select by highlighting the primary demand input to be read into the SMS Suite
2. Click on the **putmatrix** button shown in the EXCEL sheet that is linked to Matlab Excel Link
3. Give the input matrix a name

Note:

1. If you plan to use the primary demand input many more times in the future runs it is best to save it in a file otherwise it will be lost as you end the SMS run session.
2. When subscribed, the SMS also models PJM, New England ISO for accurate representation of power flow, the primary demands for these control areas will be provided in a default database to be used in conjunction with other primary demands prepared by users. This feature will be discussed in the next section.
3. At any time, users could replace previous primary demand forecasts by more accurate and recent sources based on the weather actual such as IMO or NY ISO forecasts. The next section will show how this can be done.

g) Run_SMS:

Finally, the **Run_SMS** worksheet is to read into the SMS program all the changes that have been made so far. Here one must also specify the primary demand forecasts that are required as inputs to the program, and whether there is any holiday during the period of study, if so, specify them, and then run the study using the SMS program.

The screenshot shows the 'Holiday 03' worksheet in Microsoft Excel. The worksheet contains several input fields and a list of holidays. A red arrow points to the first yellow cell (B3) with the instruction: "Place CURSOR in the 1st yellow cell & follow instructions".

Row	Column	Value	Description
3	B	0	Press F2, RETURN: for Current DIRECTORY
4	B	0	Press F2, RETURN: for Reading Tx INPUT Database
7	B	no	USE IMO PD and/or NYISO PD (yes/no)
9	B	01-Jan-02	Starting Date of the PD Data
11	B	31-Jul-02	Starting Date of PRICE Forecasts
12	B	15-Aug-02	Ending Date of PRICE Forecasts
13	K	Holiday 03	Header for holiday list
14	B	05-Aug-02	Holidays During This Period
14	K	01-Jan-03	
15	K	18-Apr-03	
16	K	21-Apr-03	
17	K	19-May-03	
18	K	01-Jul-03	
19	K	04-Aug-03	
20	K	01-Sep-03	
21	K	04-Oct-03	
22	K	25-Dec-03	
23	K	26-Dec-03	
35	B	0	
36	B		To run SMS, go to Command Window and TYPE:
37	B		runSMS

Although the steps are self-explanatory, let us go through the example shown in details.

Once the SMS Suite has been activated with Excel link ready, the steps to be taken to run the SMS program is as follows:

1. Put the cursor in the first yellow cell and press F2 to locate the default directory that is the home of all the input-output data.
2. Press F2 with the cursor in the next yellow cell to read network database together with all the changes made.
3. Decide whether IMO Primary Demand (PD) forecast should be used or the in-house PD forecast is the choice. In the example shown here, it is assumed that the in-house PD forecast is supplied for the entire year 2002. Thus, the starting date of the PD forecast is Jan. 1, 2002. One can easily change this date according to the PD forecast prepared for the study.
4. Record the starting date and ending date for the study period.
5. Record any holidays that might fall between the study periods. This is useful for the program to decide on-peak, off-peak and weekend prices. Also because US and Canada may have different holidays during the course of a month or a year, it is important that the data be input manually to avoid confusion and error.
6. Move the cursor to the next yellow cell and press F2 to record input data about holidays and/or the source of PD forecast.
7. Go to the Matlab command window and run the SMS Suite by issuing the command **"runSMS."**

However, before issuing this command to execute the program, users may want to decide whether simple simulation run or Monte Carlo simulation run is indeed the choice. To make this choice, you must go back to the **BID_ASK** worksheet, and under the parameter **MC** (stands for Monte Carlo) enter the desired option: 1 to run Monte Carlo and 0 to make a simple (non-Monte Carlo) simulation run. Further to this choice, one must also enter what level of uncertainty in the PD forecast and the number of iterations required for each hour one wish to entertain. Suppose the PD uncertainty is around 3 % and 10 iterations are needed, then enter in the parameter beneath the cell labeled **MCsd** (stands for Monte Carlo Standard Deviation) the value 0.03, and beneath the parameter cell labeled **MCiter** enter 10. See the diagram below.

Note: One must go back to the second yellow cell at the top to read in these changes before issuing the "runSMS" command to run the SMS Suite.

Microsoft Excel - SMS_DataBase4Use_IMOPD.xls

File Edit View Insert Format Tools Data Window Help

Arial 10 B I U \$ % , +.00 +.0

B528 =

	AO	AP	AQ	AR	AS	AT	AU	AV	AW	AX	AY	BJ
1												
2	PerFac	0.65	0.6	1	1.05							
3	Yes: 1	MC	NuTxLim	MCiter	MCsd	PFOfactor	AdjTxLim	GenOutag	Imp/Exp	ORBid		
4	No: 0	1	1	10	0.03	0.15	1	0	0	0		
5	MCerto	1	2	3	4	5	6	7	8	9		
6	Enter Options as necessary in the above cells and move to the next sheet (SMS_run) to run											
7												
8												
9												
10												
11												

These cells are to be used for Monte Carlo Simulation run:

1. MC = 1: Yes , use MC, MC = 0: No MC.
2. Mciter = 10, use 10 iterations for each hour, used only when MC = 1.
3. MCsd = 0.03, PD uncertainty is around 3 %, used only when MC = 1.

4. SMS OUTPUTS

When subscribed with the appropriate modules, the output of SMS program includes three main sets of power market forecasts: spot market price forecasts, flowgates' flows and transmission right and/TCC value. In the following sections, each of these output feature will be presented in details:

a) Spot Market Price Forecasts:

The spot market price forecasts are processed into 4 main blocks (categories) to help users best utilize the SMS output results. They are

- **7x24 Price Block:** Contains simple and weighted average daily prices
- **5x16 Price Block:** Contains simple and weighted average daily prices for the weekdays' hours 7:00 – 22:00
- **5x8 Price Block:** Contains simple and weighted average daily prices for the weekdays' hours 1:00 – 6:00 and 23:00 – 24:00
- **2x24 Price Block:** Contains simple and weighted average daily price for the weekends and holidays

There are two ways to obtain these results from a SMS run. The easiest way is to point the cursor at the yellow cell in the first row of the **SMSSpotPrices** output worksheet and press **F2**. Using this approach users will have all the results printed all at once in the pre-arranged SMS output worksheet.

0 Place Cursor in the yellow cell and press F2 for Price Results																											
7x24 Price Block					5x16 Price Block					5x8 Price Block					2x24 Price Block												
MCP7x24	MCPs	\$C	MCPw	\$C	DailyPD	GWt	MCP5x16	MCPs	\$C	MCPw	\$C	DailyPD	GWt	MCP5x8	MCPs	\$C	MCPw	\$C	DailyPD	GWt	MCP2x24	MCPs	\$C	MCPw	\$C	DailyPD	GWt
15-Jul-02	63.8		65.1		443		15-Jul-02	79.5		81.5		321		15-Jul-02	32.2		32.3		122		20-Jul-02	36.7		37.2		384	
16-Jul-02	60.7		62.3		415		16-Jul-02	75.5		77.9		298		16-Jul-02	31.0		31.1		117		21-Jul-02	35.0		35.4		376	
17-Jul-02	64.6		66.7		414		17-Jul-02	80.1		83.1		297		17-Jul-02	33.5		33.8		116		27-Jul-02	37.1		37.6		412	
18-Jul-02	79.7		80.5		418		18-Jul-02	101.9		102.9		302		18-Jul-02	35.4		35.6		116		28-Jul-02	32.1		32.3		372	
19-Jul-02	58.8		60.0		422		19-Jul-02	71.6		73.2		305		19-Jul-02	33.2		33.5		117		3-Aug-02	33.0		33.3		384	
20-Jul-02	36.7		37.2		384		22-Jul-02	70.7		72.4		293		22-Jul-02	31.0		31.1		115		4-Aug-02	31.9		32.2		367	
21-Jul-02	35.0		35.4		376		23-Jul-02	69.9		71.6		303		23-Jul-02	32.2		32.4		116		10-Aug-02	39.3		40.0		405	
22-Jul-02	57.4		58.7		408		24-Jul-02	74.6		75.4		327		24-Jul-02	34.2		34.4		125		11-Aug-02	35.1		35.7		365	
23-Jul-02	57.4		58.5		419		25-Jul-02	71.7		72.2		313		25-Jul-02	31.7		31.8		120		5-Aug-02	39.8		40.8		376	
24-Jul-02	61.2		61.7		452		26-Jul-02	66.6		67.4		325		26-Jul-02	31.1		31.2		124								
25-Jul-02	58.4		58.7		433		29-Jul-02	89.0		89.8		324		29-Jul-02	32.5		32.5		122								
26-Jul-02	54.8		55.3		449		30-Jul-02	89.9		93.3		329		30-Jul-02	34.7		35.1		125								
27-Jul-02	37.1		37.6		412		31-Jul-02	74.0		76.3		292		31-Jul-02	33.0		33.2		115								
28-Jul-02	32.1		32.3		372		1-Aug-02	88.2		90.2		309		1-Aug-02	36.0		36.3		118								
29-Jul-02	70.1		70.7		446		2-Aug-02	82.0		84.8		316		2-Aug-02	34.8		35.2		121								
30-Jul-02	74.5		73.0		454		3-Aug-02	88.0		74.0		300		3-Aug-02	34.4		34.3		119								

This is the CIVIC holiday during the period from July 15 - August 15, 2002

Sometimes, users would also like the flexibility to store the desired price output in a place other than the pre-arranged worksheet. To accommodate this desire, SMS allows users to select individual price blocks and store at any location of their choice. The names for each individual price block are:

- **7x24 Price Block:** MCP7x24
- **5x16 Price Block:** MCP5x16
- **5x8 Price Block:** MCP5x8
- **2x24 Price Block:** MCP2x24

To store a particular price block at a desire location of an EXCEL worksheet, all one has to do is to follow the steps:

- Go to the location where the data is to be stored and,
- Click on the **getmatrix** button
- Enter the name of the price block to be stored in the menu and hit Enter or the OK button on the MENU

The screenshot shows the Microsoft Excel interface with a worksheet titled 'SMSOutPuts.xls'. The worksheet contains a table with the following data:

7x24 Price Block				
MCP7x24	MCPs \$C	MCPw \$C	DailyPD	GWh
15-Jul-02	63.8	65.1	443	
16-Jul-02	60.7	62.3	415	
17-Jul-02	64.6	66.7	414	
18-Jul-02	79.7	80.5	418	
19-Jul-02	58.8	60.0	422	
20-Jul-02	36.7	37.2	384	
21-Jul-02	35.0	35.4	376	
22-Jul-02	57.4	58.7	408	
23-Jul-02	57.4	58.5	419	
24-Jul-02	61.2	61.7	452	
25-Jul-02	58.4	58.7	433	
26-Jul-02	54.8	55.3	449	
27-Jul-02	37.1	37.6	412	
28-Jul-02	32.1	32.3	372	
29-Jul-02	70.1	70.7	446	
30-Jul-02	71.5	73.9	454	

The dialog box 'Microsoft Excel' is open, showing the 'Name of Matrix to get from MATLAB' field with 'MCP7x24' entered. The 'OK' button is highlighted.


Annotations in the image include:

- Step 1:** A box pointing to the date '15-Jul-02' in the table.
- Step 2:** A box pointing to the 'getmatrix' button in the Excel menu.
- Step 3:** A box pointing to the 'MCP7x24' text in the dialog box.

b) Flowgate 's Flows:

All critical flowgates as observed by IMO/ISO are defined in Appendix A. The flowgate 's flow results can be obtained by place the cursor at the desired location and follow the same steps as shown in the last section:

- Go to the location where the data is to be stored and,
- Click on the **getmatrix** button
- Enter the name **FinFLOW** (for flowgates' flows) in the menu and hit Enter or the OK button on the MENU



c) Congested Flowgates & FTR Values:

SMS program also determines hourly what flowgates are being congested and what amount of power flows in each of the congested flowgates. These features are useful for determining the values of the Financial Transmission Rights (FTR) administered the IMO or the Transmission Congestion Contract managed by the New York ISO. The sample picture below shows typical results obtained after each SMS run.


Interface		FTRwhere CONGESTED FLOWGATES								FTRvalue CONGESTED ENERGY (MWh)							
No	Interface	Hrs								Hrs							
1	TFM	1	21	27	29	34	0	0	0	1	2600	3700	1300	1100	0	0	0
2	LHE	2	27	29	34	0	0	0	0	2	3700	1300	1100	0	0	0	0
3	EWFEA	3	27	29	34	0	0	0	0	3	3700	1300	1100	0	0	0	0
4	D501P	4	27	29	34	0	0	0	0	4	3700	1300	1100	0	0	0	0
5	P502X	5	27	29	34	0	0	0	0	5	3700	1300	1100	0	0	0	0
6	FN_S	6	21	27	29	34	0	0	0	6	230	2600	3700	1300	1100	0	0
7	QFW	7	21	27	29	34	0	0	0	7	230	2600	3700	1300	1100	0	0
8	BLIP	8	21	26	27	37	0	0	0	8	230	2600	4225	3700	-1500	0	0
9	FETT	9	21	25	26	27	37	0	0	9	230	-200	4225	3700	-1500	0	0
10	MH-ONT	10	21	25	26	27	37	0	0	10	230	1200	4225	3700	-1500	0	0
11	ONT-MPL	11	21	25	26	27	37	0	0	11	230	-1200	4225	3700	-1500	0	0
12	ONT-MECS	12	25	26	27	33	37	0	0	12	-1200	4225	3700	-550	-1500	0	0
13	ONT-NYPP	13	25	26	27	33	37	0	0	13	-1200	4225	3700	-550	-1500	0	0
14	NTxONT_STL	14	25	26	27	33	37	0	0	14	-1200	4225	3700	-550	-1500	0	0

The numbers reported in the **FTRwhere** table on the right are the indices to the **Interface** (Flowgate) table on the left. Thus, **2** refers to **LHE** flowgate

The flowgate # 2 (or LHE) limit was reached at 230MW from hour 6 through hour 11 in this example.


To obtain a report of hourly congested flowgates, do as follows:

- Place the cursor at the cell just immediate right of hour 1
- Click on the **getmatrix** button
- Then type **FTRwhere** on the appeared MENU



Similarly, to examine the value of the power flow in the congested flowgates, do the following steps:

- Place the cursor at the cell just immediate right of hour 1 of FTRvalue table
- Click on the **getmatrix** button
- Then type **FTRvalue** on the appeared MENU



APPENDIX A: FLOW-GATE DEFINITIONS

The following are the definitions of northeastern interconnection critical flowgates as defined by NERC NPCC and local IMO/ISO. The bus names and bus numbers are based on the NERC base-case loadflow.

FROM Bus NUMBER	TO Bus NUMBER	Low Tx. LIMIT	High	FROM Bus NAME	TO Bus NAME	Circuit IDENTIFIER
% 1: TEM						
82275	82270	-350	325	MACKENZI 220	LAKEHEAD 220	CCT= 1
82275	82270	-350	325	MACKENZI 220	LAKEHEAD 220	CCT= 2
82429	82320	-350	325	MURILLO 118.05	BIRCH 118.05	CCT= 1
% 2: LHE						
82270	82280	-250	230	LAKEHEAD 220	MARATHON 220	CCT= 1
82270	82280	-250	230	LAKEHEAD 220	MARATHON 220	CCT= 2
% 3: EWFE						
82280	81970	-350	325	MARATHON 220	WAWA 220	CCT= 1
82280	81970	-350	325	MARATHON 220	WAWA 220	CCT= 2
% 4: D501P						
80081	80066	-1500	1500	PINARD 500	PORCUPIN 500	CTT= 1
% 5: P502X						
80066	80056	-1500	1500	PORCUPIN 500	HANMER 500	CCT= 1
% 6: FN_S						
80056	80046	-1800	1265	HANMER 500	ESSA 500	CCT= 1
80056	80046	-1800	1265	HANMER 500	ESSA 500	CCT= 2
81940	81160	-1800	1265	OTTO HOL 220	DES JOAC 220	CCT= 1
% 7: QFW						
81500	81597	-1600	1350	BECK2 DK 220	NEALJQ23 220	CCT= 1
81500	81595	-1600	1350	BECK2 DK 220	HANONJ24 220	CCT= 1
81500	81598	-1600	1350	BECK2 DK 220	NEALJQ25 220	CCT= 1
81500	81596	-1600	1350	BECK2 DK 220	HANONJ29 220	CCT= 1
81484	81615	-1600	1350	ALANJQ30 220	MIDDLEPT 220	CCT= 1
% 8: BLIP						
81570	82550	-1500	3500	DETWEILE 220	BUCHANAN 220	CCT= 1
81570	82550	-1500	3500	DETWEILE 220	BUCHANAN 220	CCT= 2
81615	82550	-1500	3500	MIDDLEPT 220	BUCHANAN 220	CCT= 1
82585	82550	-1500	3500	SALFDJ33 220	BUCHANAN 220	CCT= 1
82586	82550	-1500	3500	SALFDJ32 220	BUCHANAN 220	CCT= 1
80009	80121	-1500	3500	WILCJ562 500	LONGWOOD 500	CCT= 1
80010	80121	-1500	3500	WILCJ563 500	LONGWOOD 500	CCT= 1
80116	80121	-1500	3500	NANTICOK 500	LONGWOOD 500	CCT= 1

% 9: FETT

80101	80041	-5000	5750	MILTON	500	CLAIRVIL	500	CCT=	1
80101	80041	-5000	5750	MILTON	500	CLAIRVIL	500	CCT=	2
80099	80041	-5000	5750	MILTONH1	500	CLAIRVIL	500	CCT=	1
80100	80041	-5000	5750	MILTONH2	500	CLAIRVIL	500	CCT=	1
80251	80203	-5000	5750	ORANGEVL	220	ALLISJE8	220	CCT=	1
80251	80204	-5000	5750	ORANGEVL	220	ALLISJE9	220	CCT=	1
80731	80520	-5000	5750	TRAFALGA	220	ERINJR14	220	CCT=	1
80731	80521	-5000	5750	TRAFALGA	220	ERINJR17	220	CCT=	1
80731	80519	-5000	5750	TRAFALGA	220	ERINJR19	220	CCT=	1
80731	80518	-5000	5750	TRAFALGA	220	ERINJR21	220	CCT=	1

% 10: MH_ONT

63457	82260	-200	300	WHTSL1	4	220	KENORA	220	CCT=	1
63490	82260	-200	300	WHTSL2	4	220	KENORA	220	CCT=	1

% 11: ONT_MPL

82365	61484	-150	175	FT FRANC	118.05	INTPHAS7	115	CCT=	1
-------	-------	------	-----	----------	--------	----------	-----	------	---

% 12: ONT_MECS

82645	79002	-2214	2344	SCOTT	220	19BUNCEP	230	CCT=	1
82590	28805	-2214	2344	J5D PS	230	19WTRMN	230	CCT=	1
82695	28786	-2214	2344	LAMB L4D	345	19STCPP	345	CCT=	1
82696	28786	-2214	2344	LAMB L51	345	19STCPP	345	CCT=	1

(NERC_LF00)

% 13: ONT_NYPP

81256	79589	-2500	2500	STLAWL33	230	MOSES E	230	CCT=	1
81255	79589	-2500	2500	STLAWL34	230	MOSES E	230	CCT=	1
81508	79584	-2500	2500	BECK B	345	NIAG	345 345	CCT=	1
81509	79584	-2500	2500	BECK A	345	NIAG	345 345	CCT=	1
81516	79592	-2500	2500	PA27 REG	230	NIAGAR2W	230	CCT=	1
81515	76665	-2500	2500	BP76 REG	230	PACKARD2	230	CCT=	1

% 14: NYxONT_STL

79589	81256	-450	450	MOSES E	230	STLAWL33	230	CCT=	1
79589	81255	-450	450	MOSES E	230	STLAWL34	230	CCT=	1

% 15: NY_CxE

79583	78703	-3100	3100	MARCY T1	345	N.SCOT99	345	CCT=	1
78450	78702	-3100	3100	EDIC	345	N.SCOT77	345	CCT=	1
78460	78980	-3100	3100	PORTER 2	230	ROTRDM.2	230	CCT=	1
78460	78980	-3100	3100	PORTER 2	230	ROTRDM.2	230	CCT=	2
78478	99892	-3100	3100	78460INGMS-CD	115	79136:INGHAM-E115	CCT=1->PAR:78478-		
99892<-									
75447	79136	-3100	3100	E.SPR115	115	INGHAM-E	115	CCT=	1
79602	70511	-3100	3100	PLAT T#3	115	GRAND IS	115	CCT=	1

% 16: NY_WxC

79801	77400	-2350	2350	PANNELL3	345	CLAY	345	CCT=	1
79801	77400	-2350	2350	PANNELL3	345	CLAY	345	CCT=	2
75417	75414	-2350	2350	STOLE230	230	MEYER230	230	CCT=	1
76510	76539	-2350	2350	ANDOVER1	115	NILE115	115	CCT=	99
79805	77433	-2350	2350	CLYDE199	115	CLTNCORN	115	CCT=	1
79875	77447	-2350	2350	FARMNGTN34.5		FRMGTN-4	115	CCT=	1

79875	77444	-2350	2350	FARMNGTN34.5	FARMGTN1	115	CCT=	1
77111	77110	-2350	2350	MORTIMER	LAWLER-1	115	CCT=	1
77111	77463	-2350	2350	MORTIMER	LAWLER-2	115	CCT=	1
79825	77447	-2350	2350	PANNELLI	FRMGTN-4	115	CCT=	1
79826	75892	-2350	2350	QUAKER	MACDN115	115	CCT=	1
79826	75893	-2350	2350	QUAKER	SLEIG115	115	CCT=	1
79805	75893	-2350	2350	CLYDE199	SLEIG115	115	CCT=	1
79810	75995	-2350	2350	STA 162	S.PER115	115	CCT=	1

% 17: NYxPJM

76501	361	-3600	3600	S RIPLEY	ERIE E	230	CCT=	1
76527	281	-3600	3600	FALCONER	WARREN	115	CCT=	1
75406	479	-3600	3600	STOLE345	HOMER CY	345	CCT=	1
75407	479	-3600	3600	WATRC345	HOMER CY	345	CCT=	1
75413	382	-3600	3600	HILSD230	E.TWANDA	230	CCT=	1
75486	383	-3600	3600	N.WAV115	E.SAYRE	115	CCT=	1
75457	387	-3600	3600	GOUDY115	LAUREL L	115	CCT=	1
74300	2	-3600	3600	RAMAPO 5	BRANCHBG	500	CCT=	1
79302	5028	-3600	3600	SMAHWAH1	WALDWICK	345	CCT=	1
79303	5028	-3600	3600	SMAHWAH2	WALDWICK	345	CCT=	1
74328	4989	-3600	3600	FARRGUT1	HUDSON1	345	CCT=	1
74329	5039	-3600	3600	FARRGUT2	HUDSON2	345	CCT=	1
74371	4996	-3600	3600	GOETHALS	LINDEN	230	CCT=	1

% 18: PJMxWEST

11	9	-5750	5750	KEYSTONE	JUNIATA	500	CCT=	1
5	9	-5750	5750	CONEM-GH	JUNIATA	500	CCT=	1
5	26	-5750	5750	CONEM-GH	HUNTERTN	500	CCT=	1
20105	3	-5750	5750	01DOUBS	BRIGHTON	500	CCT=	1

% 19: PJMxCEN

11	9	-4500	4500	KEYSTONE	JUNIATA	500	CCT=	1
5	9	-4500	4500	CONEM-GH	JUNIATA	500	CCT=	1
4	13	-4500	4500	CNASTONE	PEACHBTM	500	CCT=	1

% 20: PJMxEAST

23	1	-7000	7000	WESCOVLE	ALBURTIS	500	CCT=	1
9	1	-7000	7000	JUNIATA	ALBURTIS	500	CCT=	1
16	8	-7000	7000	3 MILE I	HOSENSAK	500	CCT=	1
13	24	-7000	7000	PEACHBTM	LIMERICK	500	CCT=	1
13	10	-7000	7000	PEACHBTM	KEENEY	500	CCT=	1

% 21: FRNT_GENE

75404	79800	-2750	2750	KINTI345	ROCH	345	345	CCT=	1
79584	79800	-2750	2750	NIAG	ROCH	345	345	CCT=	1
75417	75414	-2750	2750	STOLE230	MEYER230	230	230	CCT=	1
76702	77122	-2750	2750	LOCKPORT	SOUR-111	115	115	CCT=	1
76702	77101	-2750	2750	LOCKPORT	SHEL-113	115	115	CCT=	1
76702	77126	-2750	2750	LOCKPORT	TELRDTP2	115	115	CCT=	1
76702	77117	-2750	2750	LOCKPORT	OAKFLDTP	115	115	CCT=	1
76702	77115	-2750	2750	LOCKPORT	NAKR-108	115	115	CCT=	1
76702	77125	-2750	2750	LOCKPORT	TELRDTP1	115	115	CCT=	1
75994	75992	-2750	2750	PALMT115	BENET115	115	115	CCT=	1

% 22: GENE_CEN

79801	77400	-2350	2350	PANNELL3	345	CLAY	345	CCT=	1
79801	77400	-2350	2350	PANNELL3	345	CLAY	345	CCT=	2
75417	75414	-2350	2350	STOLE230	230	MEYER230	230	CCT=	1
77111	77110	-2350	2350	MORTIMER	115	LAWLER-1	115	CCT=	1
77111	77463	-2350	2350	MORTIMER	115	LAWLER-2	115	CCT=	1
79826	75893	-2350	2350	QUAKER	115	SLEIG115	115	CCT=	1
79825	77447	-2350	2350	PANNELLI	115	FRMGTN-4	115	CCT=	1
79810	75995	-2350	2350	STA 162	115	S.PER115	115	CCT=	1
79826	75892	-2350	2350	QUAKER	115	MACDN115	115	CCT=	1
75994	75992	-2350	2350	PALMT115	115	BENET115	115	CCT=	1
79805	75893	-2350	2350	CLYDE199	115	SLEIG115	115	CCT=	1
79805	77433	-2350	2350	CLYDE199	115	CLTNCORN	115	CCT=	1
79875	77444	-2350	2350	FARMNGTN34.5		FARMGTN1	115	CCT=	1
79875	77447	-2350	2350	FARMNGTN34.5		FRMGTN-4	115	CCT=	1
79946	77447	-2350	2350	S168	12.0	FRMGTN-4	115	CCT=	1

% 23: ADIR_CEN

79578	79577	-2000	2000	MASS 765	765	MARCY765	765	CCT=	1
78017	78002	-2000	2000	DENNISON	115	ANDRWS-4	115	CCT=	1
79590	79585	-2000	2000	MOSES W	230	ADRON B1	230	CCT=	1
79590	79586	-2000	2000	MOSES W	230	ADRON B2	230	CCT=	1
78017	78032	-2000	2000	DENNISON	115	LWRNCE-B	115	CCT=	1
78000	78010	-2000	2000	ALCOA-NM	115	BRADY	115	CCT=	1
78033	78041	-2000	2000	MALONE	115	NICHOLVL	115	CCT=	1

% 24: CENxCAP-HUD

78450	78702	-4650	4650	EDIC	345	N.SCOT77	345	CCT=	1
79583	78703	-4650	4650	MARCY T1	345	N.SCOT99	345	CCT=	1
78460	78980	-4650	4650	PORTER 2	230	ROTRDM.2	230	CCT=	1
78460	78980	-4650	4650	PORTER 2	230	ROTRDM.2	230	CCT=	2
75447	79136	-4650	4650	E.SPR115	115	INGHAM-E	115	CCT=	1
78478	99892	-4650	4650	78478:INGMS-CD115		79136:INGHAM-E115CCT=1->PAR:78478-			
99892	<-								
75403	79581	-4650	4650	FRASR345	345	GILB	345 345	CCT=	1
79304	74001	-4650	4650	SHOEMTAP	345	ROCK TAV	345	CCT=	1
75400	74001	-4650	4650	COOPC345	345	ROCK TAV	345	CCT=	2

% 25: CAPxNE

79135	70522	-1200	1200	HOOSICK	115	BNNINGTN	115	CCT=	1
79167	70525	-1200	1200	WHITEHAL	115	BLISSVIL	115	CCT=	1
78980	72385	-1200	1200	ROTRDM.2	230	BRSWAMP	230	CCT=	1
78700	72928	-1200	1200	ALPS345	345	MANY393	345	CCT=	1
74344	73117	-1200	1200	PLTVLLEY	345	CTNY398	345	CCT=	1

% 26: CAPxWSCHE

74002	74331	-5100	5100	ROSETON	345	FISHKILL	345	CCT=	1
74344	74341	-5100	5100	PLTVLLEY	345	MILLWOOD	345	CCT=	1
74344	74331	-5100	5100	PLTVLLEY	345	FISHKILL	345	CCT=	1
74344	74331	-5100	5100	PLTVLLEY	345	FISHKILL	345	CCT=	2
74344	74356	-5100	5100	PLTVLLEY	345	WOOD B	345	CCT=	1
74347	74312	-5100	5100	RAMAPO	345	BUCH N	345	CCT=	1
74340	74313	-5100	5100	LADENTWN	345	BUCH S	345	CCT=	1
74026	75762	-5100	5100	FISHKILL	115	SYLVN115	115	CCT=	1
74022	74331	-5100	5100	E FISH I	115	FISHKILL	345	CCT=	1

% 27: WSCHExNYC

74420	74533	-4175	4175	DUN NO1R	138	S CREEK	138	CCT=	1
74421	74533	-4175	4175	DUN NO2R	138	S CREEK	138	CCT=	1
74424	74435	-4175	4175	DUN SO1R	138	E179 ST	138	CCT=	1
74316	74345	-4175	4175	DUNWODIE	345	RAINEY	345	CCT=	3
74316	74345	-4175	4175	DUNWODIE	345	RAINEY	345	CCT=	4
74348	74351	-4175	4175	SPRBROOK	345	TREMONT	345	CCT=	1
74348	74354	-4175	4175	SPRBROOK	345	W 49 ST	345	CCT=	1
74348	74354	-4175	4175	SPRBROOK	345	W 49 ST	345	CCT=	2
75047	74505	-4175	4175	L SUCSPH	138	JAMAICA	138	CCT=	1
75067	74505	-4175	4175	V STRM P	138	JAMAICA	138	CCT=	1

% 28: NYCxLILCO

74505	75047	-550	550	JAMAICA	138	L SUCSPH	138	CCT=	1
74505	75067	-550	550	JAMAICA	138	V STRM P	138	CCT=	1

% 29: WSCHExLILCO

74316	75000	-625	625	DUNWODIE	345	SHORE RD	345	CCT=	1
74348	79607	-625	625	SPRBROOK	345	DVNPT NK	345	CCT=	1

% 30: NPXxLILCO

73166	75053	-150	175	NORHR138	138	NRTHPT P	138	CCT=	1
-------	-------	------	-----	----------	-----	----------	-----	------	---

% 31: PJM WxCAP

2	74300	-1150	1150	BRANCHBG	500	RAMAPO 5	500	CCT=	1
5028	79302	-1150	1150	WALDWICK	345	SMAHWAH1	345	CCT=	1
5028	79303	-1150	1150	WALDWICK	345	SMAHWAH2	345	CCT=	1

% 32: PJM ExNYC

5039	74329	-400	400	HUDSON2	345	FARRGUT2	345	CCT=	1
4989	74328	-400	400	HUDSON1	345	FARRGUT1	345	CCT=	1
4996	74371	-400	400	LINDEN	230	GOETHALS	230	CCT=	1

% 33: PJM WxNIAG

479	75406	-1100	1100	HOMER CY	345	STOLE345	345	CCT=	1
281	76527	-1100	1100	WARREN	115	FALCONER	115	CCT=	1
361	76501	-1100	1100	ERIE E	230	S RIPLEY	230	CCT=	1

% 34: PJM WxCEN

387	75457	-1300	1300	LAUREL L	115	GOUDY115	115	CCT=	1
383	75486	-1300	1300	E.SAYRE	115	N.WAV115	115	CCT=	1
382	75413	-1300	1300	E.TWANDA	230	HILSD230	230	CCT=	1
479	75407	-1300	1300	HOMER CY	345	WATRC345	345	CCT=	1

% 35: HQxADIR

84819	79578	-2350	2350	CHA-NY82	765	MASS 765	765	CCT=	1
89378	78017	-2350	2350	ROSEMT	115	DENNISON	115	CCT=	1 O/S
89379	78017	-2350	2350	ROSEMT-	115	DENNISON	115	CCT=	1 O/S

% 36: NEPOOLxNY

70511	79602	-1900	1900	GRAND IS	115	PLAT T#3	115	CCT=	1
70522	79135	-1900	1900	BNNINGTN	115	HOOSICK	115	CCT=	1
70525	79167	-1900	1900	BLISSVIL	115	WHITEHAL	115	CCT=	1
72385	78980	-1900	1900	BRSWAMP	230	ROTRDM.2	230	CCT=	1
72928	78700	-1900	1900	MANY393	345	ALPS345	345	CCT=	1
73117	74344	-1900	1900	CTNY398	345	PLTVLLEY	345	CCT=	1
73166	75053	-1900	1900	NORHR138	138	NRTHPT P	138	CCT=	1

% 37: PJMxAPS

3	20105	-1500	4000	BRIGHTON	500	01DOUBS	500	CCT=	1
11	20104	-1500	4000	KEYSTONE	500	01CABOT	500	CCT=	1
11	20116	-1500	4000	KEYSTONE	500	01YUKON	500	CCT=	1
473	20253	-1500	4000	BLAIRSVL	138	01SOCIAL	138	CCT=	1
571	20174	-1500	4000	BROOKVLE	138	01ELKO	138	CCT=	1
571	20224	-1500	4000	BROOKVLE	138	01N BETH	138	CCT=	1
375	370	-1500	4000	FARM VLY	115	TWOMILE	115	CCT=	1
283	20175	-1500	4000	FOREST	230	01ELKO	230	CCT=	1
472	20470	-1500	4000	GARRETT	115	01GARRET	115	CCT=	1
409	20220	-1500	4000	GROVER	230	01MOSHAN	230	CCT=	1
214	20248	-1500	4000	LEWISTWN	230	01SHINGL	230	CCT=	1
285	20151	-1500	4000	PINEY	115	01BURMA	115	CCT=	1
233	20188	-1500	4000	ROXBURY	138	01GREENE	138	CCT=	1
419	20220	-1500	4000	SHAWVL 1	230	01MOSHAN	230	CCT=	1
376	20234	-1500	4000	GOLD	115	01POTTER	115	CCT=	1
435	20175	-1500	4000	SHAWVL 2	230	01ELKO	230	CCT=	1
435	20248	-1500	4000	SHAWVL 2	230	01SHINGL	230	CCT=	1
1211	20463	-1500	4000	GERMANTN	138	01TANEY	138	CCT=	1
7002	20456	-1500	4000	STATIONH	230	01AQUEDT	230	CCT=	1
7002	20459	-1500	4000	STATIONH	230	01DOUBS	230	CCT=	1

% 38: PJMxCEI

302	21475	-700	700	ERIE W	345	02AT	345	CCT=	1
-----	-------	------	-----	--------	-----	------	-----	------	---

% 39: PJMxVP

19	14922	-2000	2000	BURCHES	500	8POSSUM	500	CCT=	1
7001	14072	-2000	2000	DICKERSN	230	6PL VIEW	230	CCT=	1

% 40: APS_WxE

20104	11	-5000	5000	01CABOT	500	KEYSTONE	500	CCT=	1
20116	11	-5000	5000	01YUKON	500	KEYSTONE	500	CCT=	1
20103	20101	-5000	5000	01BLACKO	500	01BEDNGT	500	CCT=	1
14917	20105	-5000	5000	8MT STM	500	01DOUBS	500	CCT=	1

% 41: ADIRxVER

79602	70511	-125	140	PLAT T#3	115	GRAND IS	115	CCT=	1
-------	-------	------	-----	----------	-----	----------	-----	------	---

% 42: NYxONT_NIA

79584	81509	-1900	1900	NIAG 345	345	BECK A	345	CCT=	1
79584	81508	-1900	1900	NIAG 345	345	BECK B	345	CCT=	1
76665	81515	-1900	1900	PACKARD2	230	BP76 REG	230	CCT=	1
79592	81516	-1900	1900	NIAGAR2W	230	PA27 REG	230	CCT=	1

% 43: DECO_CONS

28727	28328	-3000	3000	19CUSTR	120	18WHTNGA	120	CCT=	1
28736	28262	-3000	3000	19GENOA	138	18LATSON	138	CCT=	1

28741	28247	-3000	3000	19HUNTC	120	18HMPHLD	120	CCT=	1
28745	28309	-3000	3000	19JEWEL	345	18THETFR	345	CCT=	1
28747	29321	-3000	3000	19LARK	138	18WSHTNJ	138	CCT=	1
28754	28285	-3000	3000	19MAJTC	345	18ONEIDJ	345	CCT=	1
28754	28314	-3000	3000	19MAJTC	345	18TOMPKN	345	CCT=	1
28774	28245	-3000	3000	19PONTC	345	18HAMPTO	345	CCT=	1
28815	28198	-3000	3000	19ATLAN	138	18ATLNTJ	138	CCT=	1

% 44: DECO_AEP

28750	21465	-2000	2000	19LULU	345	02ALLEN	345	CCT=	1
28754	21460	-2000	2000	19MAJTC	345	02LEMOY	345	CCT=	1
28761	21455	-2000	2000	19MON12	345	02BAY SH	345	CCT=	1

% 45: CONS_AEP

28197	22670	-2500	2500	18ARGENT	345	05ROB PK	345	CCT=	1
28197	22675	-2500	2500	18ARGENT	345	05TWIN B	345	CCT=	1
28289	22652	-2500	2500	18PALISA	345	05BENTON	345	CCT=	1
28289	22654	-2500	2500	18PALISA	345	05COOK	345	CCT=	1

% 46: CONS_CIN

28200	28017	-200	200	18BATAVI	138	17BRTNLK	138	CCT=	1
-------	-------	------	-----	----------	-----	----------	-----	------	---